

Test Report



Korea Marine Equipment
Research Institute

24-20, Noksansandan 335-ro, Gangseo-gu, Busan 46754, Rep. of Korea
Tel +82-51-400-5100, Fax +82-51-400-5191

Report No. :

KOMERI-0307-18T1580

<http://www.komeri.re.kr>



1. Applicant

- Company Name : SEGIBIZ CO., LTD
- Address : (46989) 32, Saebyeoksijang-ro, Sasang-Gu, Busan, Korea
- Date of Receipt : 2018, 04, 24

2. Equipment under Test

- Name of Product : Plastic Terminal Box
- Model : SG-TB-15PT
- Serial No. : -

3. Test Standards : IEC 60529:1989+AMD1:1999+AMD2:2013 Degree of protection provided by enclosure (IP CODE)

4. Use of Report : Quality verification

5. Test Period : 2018. 05. 02 ~ 2018. 05. 03

6. Environment : Refer to detailed Test Environments

7. Test Result : Conformity(IP65)

The result shown in this test report refer only to the sample(s) tested unless otherwise stated.

| | | |
|-------------|---------------------|-----------------------|
| Affirmation | Tested by | Technical Manager |
| | Name : Sang-Jin LEE | Name : Bong-Yeol CHOI |

This test certificate is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.

Date of issue : 2018, 05, 11

Accredited by KOLAS, Republic of KOREA


The President of Korea Marine Equipment Research Institute





TABLE OF CONTENTS

| | |
|-----------------------------|----|
| ■ GENERAL | 3 |
| 1. IP6X TEST | 4 |
| 2. IPX5 TEST | 7 |
| ATTACHMENT I, DRAWING | 10 |





GENERAL

■ MANUFACTURER

Company Name : SEGIBIZ CO., LTD

Address : (46989) 32, Saebyeoksijang-ro, Sasang-Gu, Busan, Korea

■ TEST SITE

· 24-20, Noksansandan 335-ro, Gangseo-gu, Busan, Korea

■ TEST SUMMARY

| No. | Test Item | Test Standard | Result |
|-----|-----------|---|------------|
| 1 | IP6X | IEC 60529:1989+AMD1:1999+AMD2:2013 Degree of protection provided by enclosure (IP CODE) | Conformity |
| 2 | IPX5 | | Conformity |

■ ADDITIONAL TEST INFORMATION

· The result shown in this test report is only accepted to EUT applied with rated voltage not exceeding 72.5 kV.

